

May 10, 2016

TO: All Bidders

RE: Informal Bid 2016-09 Generator Project

ADDENDUM NO. 1

This **ADDENDUM #1** forms part of Moore County's Informal Bid for the Generators Project for the County of Moore Public Works Department. All requirements of the original specifications remain in effect in their respective order. **Receipt of this Addendum must be acknowledged by its inclusion with the Bid and noted as an inclusion on the sealed envelope.**

The following changes and/or clarifications are hereby made to the original Bid:

NOTE: BID OPENING DATE HAS BEEN EXTENDED UNTIL 4:00 PM MONDAY MAY 16, 2016.

- 1) Question: The specifications state that the contractor is to install a dialer at each pump station but dialers are not shown on the drawings. Do we need to plan on installing these? Also, if we do provide these, are we providing wireless/cellular dialers or wired dialers that use phone lines. Both are mentioned in the specs.
Answer: No. We will not need the auto dialers. The Aquavx and Central Security units are all we need. The contractor will be responsible to relocate them to the hood.
- 2) Question: At Lift Station PW-1, I am assuming that you want an equipment hood mounted to house the panels and disconnects. Is this hood to be constructed of aluminum or stainless steel?
Answer: No. the hood and generator are existing.
- 3) Question: Who pays for the permits? I see conflicting notes on the drawings and specs.
Answer: Moore County will pay and submit for the permit.

No further questions will be accepted. Proposals are due to Terra Vuncannon at 206 South Ray Street Carthage NC 28327 by 4:00 pm May 16, 2016.

END OF ADDENDUM NO. 1

Sincerely,

Terra Vuncannon
Purchasing Manager
County of Moore